

Idec Serial Driver Help

© 2011 Kepware Technologies

Table of Contents

Table of Contents	2
Idec Serial Driver Help	4
Overview	4
Device Setup	5
Modem Setup	5
Tag Import Settings	5
Micro3/OpenNet Contollers-RS232/RS485 Data Terminal Connection	6
FA2(J)-CP11/12-Cable Link Setup	6
Data Types Description	7
Address Descriptions	8
Micro1 Addressing	8
Micro3 Addressing	9
MicroSmart Addressing	10
OpenNet Controller Addressing	11
FA2 Addressing	13
FA2J Addressing	14
FA3S-CP11 Addressing	15
FA3S-CP12 Addressing	16
Automatic Tag Database Generation	17
Error Descriptions	19
Address Validation	19
Missing address.....	19
Device address '<address>' contains a syntax error.....	19
Address '<address>' is out of range for the specified device or register.....	20
Device address '<address>' is not supported by model '<model name>'.....	20
Data Type '<type>' is not valid for device address '<address>'.....	20
Device address '<address>' is Read Only.....	20
Serial Communications	20
COMn does not exist.....	21
Error opening COMn.....	21
COMn is in use by another application.....	21
Unable to set comm parameters on COMn.....	21
Communications error on '<channel name>' [<error mask>].....	21
Device Status Messages	22
Device '<device name>' not responding.....	22
Unable to write to '<address>' on device '<device name>'.....	22
Device Specific Messages	22
Bad address in block [<start address> to <end address>] on device '<device name>'.....	22

Automatic Tag Generation Messages..... 22

 Tag '<tag name>' not imported because model does not support type..... 23

 Error parsing import file record number <record number>..... 23

 Import file record <record number> could not be processed due to buffer overflow..... 23

 Exception encountered during tag import. Bad tag information file..... 23

 Tag import failed due to low memory resources..... 23

 Description truncated for import file record number <record number>..... 24

 Imported tag name '<old name>' is invalid. Name changed to '<new name>'..... 24

Index..... 25

Idec Serial Driver Help

Help version 1.020

CONTENTS

[Overview](#)

What is the Idec Serial Driver?

[Device Setup](#)

How do I configure a device for use with this driver?

[Data Types Description](#)

What data types does this driver support?

[Address Descriptions](#)

How do I address a data location on an Idec Serial device?

[Automatic Tag Database Generation](#)

How can I easily configure tags for the Idec Serial Driver?

[Error Descriptions](#)

What error messages does the Idec Serial Driver produce?

Overview

The Idec Serial Driver provides an easy and reliable way to connect Idec Serial controllers to OPC Client applications, including HMI, SCADA, Historian, MES, ERP and countless custom applications. It is intended for use with Idec Programmable Logic Controllers.

Device Setup

Supported Devices

Micro1
Micro3
MicroSmart
OpenNet
FA2J
FA2
FA3S-CP11
FA3S-CP12

Communication Protocol

Idec ASCII Protocol

Supported Communication Parameters

Baud Rate: 300, 600, 1200, 2400, 9600, 19200
Parity: Even, None
Data Bits: 7 (Micro3, OpenNet); 8 (All other models)
Stop Bits: 1

Ethernet Encapsulation

This driver supports Ethernet Encapsulation, which allows the driver to communicate with serial devices attached to an Ethernet network using a terminal server (such as the Lantronix DR1). It may be invoked through the COM ID dialog in Channel Properties. For more information, refer to the OPC server's help documentation.

Device IDs

Micro3 networks support up to 32 devices. Each device can be assigned a Device ID in the range of 0 to 255. All other models support up to 32 devices and should be assigned a Device ID of 0 for 1:1 communications (or a Device ID of 1-255 for 1:N communications).

Note: When multidropping, do not assign a Device ID of 0.

Flow Control

When using an RS232/RS485 converter, the type of flow control that is required depends on the needs of the converter. Some converters do not require any flow control whereas others require RTS flow. To determine the converter's flow requirements, refer to its documentation. An RS485 converter that provides automatic flow control is recommended.

Note: When using the manufacturer's supplied communications cable, it is sometimes necessary to choose a flow control setting of **RTS** or **RTS Always** under the Channel Properties.

See Also: [Tag Import Settings](#)


Cable Connections

[Micro3/OpenNet Controllers-RS232/RS485 Data Terminal Connection](#)
[FA2\(J\)-CP11/12-Cable Link Setup](#)

Modem Setup

This driver supports modem functionality. For more information, please refer to the topic "Modem Support" in the OPC server Help documentation.

Tag Import Settings




Descriptions of the parameters are as follows:


- **Tag Import File:** This parameter specifies the exact location of the WindLDR tag information file that the driver should use when automatically generating tags for the device.
- **Display Descriptions:** When checked, tag descriptions will be imported. The default setting is checked.

See Also: [Automatic Tag Database Generation](#)

Micro3/OpenNet Contollers-RS232/RS485 Data Terminal Connection



FA2(J)-CP11/12-Cable Link Setup



Data Types Description

Data Type	Description
Boolean	Single bit
Byte	Unsigned 8 bit value bit 0 is the low bit bit 7 is the high bit
Char	Signed 8 bit value bit 0 is the low bit bit 6 is the high bit bit 7 is the sign bit
Word	Unsigned 16 bit value bit 0 is the low bit bit 15 is the high bit
Short	Signed 16 bit value bit 0 is the low bit bit 14 is the high bit bit 15 is the sign bit
DWord	Unsigned 32 bit value bit 0 is the low bit bit 31 is the high bit
Float	32 bit floating point value bit 0 is the low bit bit 31 is the high bit
Long	Signed 32 bit value bit 0 is the low bit bit 30 is the high bit bit 31 is the sign bit

Address Descriptions

Address specifications vary depending on the model in use. Select a link from the following list to obtain specific address information for the model of interest.

[Micro1](#)

[Micro3](#)

[MicroSmart](#)

[OpenNet Controller](#)

[FA2](#)

[FA2J](#)

[FA3S-CP11](#)

[FA3S-CP12](#)

Micro1 Addressing

The default data types are shown in **bold**.

Data Types

Device Type	Reference	Data Type
I/O	I, Q, IF	Boolean
Internal Relays	M	Boolean
Shift Registers	R	Boolean
Timers/Counters	T, C TW, TP, CW, CP	Boolean Word, Short

Address Specifications

Address	Reference	Range	Access
Input Bits	I<xx> xx-Bit Number*	I0-I27	Read Only
Force Input Bits	IF<xx> xx-Bit Number*	IF0-IF27	Read/Write
Output Bits	Q<xx> xx-Bit Number*	Q0-Q27	Read/Write
Internal Relay Bits	M<xxx> xxx-Bit Number*	M0-M197, M300-317	Read/Write
Shift Register Bits	R<xxx> xxx-Bit Number	R0-R127	Read/Write
Counter Bits	C<xx> xx-Bit Number	C0-C46	Read Only
Counter Words	CW<xx> xx-Word Number**	CW0-CW46	Read Only
Counter Presets	CP<xx> xx-Word Number**	CP0-CP46	Read/Write
Timer Bits	T<xx> xx-Bit Number	T0-T79	Read Only
Timer Words	TW<xx> xx-Word Number**	TW0-TW79	Read Only
Timer Presets	TP<xx> xx-Word Number**	TP0-TP79	Read/Write

*Low digit octal coded.

**14 bit number.

Examples

M180	Internal relay bits 180.*
TP65	Preset value for timer 65.**
TW65	Accumulator value for timer 65.**

*Lowest digit octal coded. M108 would not be valid.

**14 bit number.

Micro3 Addressing

The default data types are shown in **bold**.

Data Types

Device Type	Reference	Data Type
I/O	I, Q, IF IW, QW	Boolean Word, Short
Internal Relays	M MW	Boolean Word, Short
Shift Registers	R RW	Boolean Word, Short
Timers/Counters	T, C TW, TP, CW, CP HW, HP	Boolean Word, Short DWord, Long
Data Registers	DW DS	Word, Short, DWord, Long, Float String
Calendar/Clock	WW	Word, Short

Address Specifications

The following memory map corresponds to the Micro3 device. The driver expands this memory range from 0 to 9999 for all memory types to support newer devices such as the Micro3C and any other future Micro3 compatible configurations.

Address	Reference	Range	Access
Input Bits/Words	I<xxx>, IW<xxx> xxx-Bit Number*	I0-I37, IW0-IW20	Read Only
Force Input Bits	IF<xxx> xxx-Bit Number*	IF0-IF37	Read/Write
Output Bits/Words	Q<xxx>, QW<xxx> xx-Bit Number*	Q0-Q37, QW0-QW20	Read/Write
Internal Relay Bits/Words	M<xxx>, MW<xxx> xxx-Bit Number*	M0-M317, MW0-MW300	Read/Write
Shift Register Bits/Words	R<xxx>, RW<xxx> xxx-Bit Number	R0-R63, RW0-RW48	Read/Write
Counter Bits	C<xx> xx-Bit Number	C0-C31	Read Only
Counter Words	CW<xx> xx-Word Number**	CW0-CW31	Read Only
Counter Presets	CP<xx> xx-Word Number**	CP0-CP31	Read/Write
Timer Bits	T<xx> xx-Bit Number	T0-T31	Read Only
Timer Words	TW<xx> xx-Word Number**	TW0-TW31	Read Only
Timer Presets	TP<xx> xx-Word Number**	TP0-TP31	Read/Write
High Speed Counter Accumulators	HW<xx> xx-HSC Accumulator Number***	HW0-HW9999	Read Only
High Speed Counter Presets	HP<xx> xx-HSC Preset Number***	HP0-HP9999	Read Only
Data Registers	DW<xxx> xxx-Word Number	DW0-DW9999	Read/Write
	DS<xxx>.<yyy> xxx-Word Number yyy-String Length (characters)	DS0.0 ... DS0.128 DS99.0 ... DS99.128	Read/Write
Calendar/Clock	WW<xxx> xxx-Word Number	WW0-WW6	Read/Write

*Low digit octal coded.

**14 bit number.

***32 bit number.

Calendar/Clock Word Numbers

0	Year (0=2000, 1=2001, etc)
1	Month
2	Day
3	Day of week (0=Sunday, 1=Monday, etc)
4	Hour (24 hour format)
5	Minute
6	Second

Examples

M180	Internal relay bits 180.*
TP65	Preset value for timer 65.**
TW65	Accumulator value for timer 65.**
DS10.24	String data stored in DW10-DW21.
WW2	Day of the month.

*Lowest digit octal coded. M108 would not be valid.

**14 bit number.

MicroSmart Addressing

The default data types are shown in **bold**.

Data Types

Device Type	Reference	Data Type
I/O	I, Q, IF IW, QW	Boolean Word , Short
Internal Relays	M MW	Boolean Word , Short
Shift Registers	R RW	Boolean Word , Short
Timers/Counters	T, C TW, TP, CW, CP HW, HP	Boolean Word , Short DWord , Long
Data Registers	DW DS	Word , Short, DWord , Long, Float String
Calendar/Clock	WW	Word , Short

Address Specifications

The following memory map corresponds to the MicroSmart device. The driver expands this memory range from 0 to 9999 for all memory types to support newer devices such as the Micro3C and any other future Micro3 compatible configurations.

Address	Reference	Range	Access
Input Bits/Words	I<xxx>, IW<xxx> xxx-Bit Number*	I0-I627, IW0-IW610	Read Only
Force Input Bits	IF<xxx> xxx-Bit Number*	IF0-IF627	Read/Write
Output Bits/Words	Q<xxx>, QW<xxx> xx-Bit Number*	Q0-Q627, QW0-QW610	Read/Write
Internal Relay Bits/Words	M<xxxx>, MW<xxxx> xxxx-Bit Number*	M0-M8317, MW0-MW8300	Read/Write
Shift Register Bits/Words	R<xxx>, RW<xxx> xxx-Bit Number	R0-R255, RW0-RW240	Read/Write
Counter Bits	C<xx> xx-Bit Number	C0-C255	Read Only

Counter Words	CW<xx> xx-Word Number**	CW0-CW255	Read Only
Counter Presets	CP<xx> xx-Word Number**	CP0-CP255	Read/Write
Timer Bits	T<xx> xx-Bit Number	T0-T255	Read Only
Timer Words	TW<xx> xx-Word Number**	TW0-TW255	Read Only
Timer Presets	TP<xx> xx-Word Number**	TP0-TP255	Read/Write
High Speed Counter Accumulators	HW<xx> xx-HSC Accumulator Number***	HW0-HW9998	Read Only
High Speed Counter Presets	HP<xx> xx-HSC Preset Number***	HP0-HP9998	Read Only
Data Registers	DW<xxxx> xxxx-Word Number	DW0-DW49999	Read/Write
	DS<xxxx>.<yyy> xxxx-Word Number yyy-String Length (characters)	DS0.0...DS0.128- DS49999.0...DS49999.128	Read/Write
Calendar/Clock	WW<x> x-Word Number	WW0-WW6	Read/Write

*Low digit octal coded.
 **16 bit number.
 ***32 bit number.

Calendar/Clock Word Numbers

0	Year (0 = 2000, 1 = 2001, etc)
1	Month
2	Day
3	Day of week (0 = Sunday, 1 = Monday, etc)
4	Hour (24 hour format)
5	Minute
6	Second

Examples

M180	Internal relay bits 180.*
TP65	Preset value for timer 65.**
TW65	Accumulator value for timer 65.**
DS10.24	String data stored in DW10-DW21.
WW2	Day of the month.

*Lowest digit octal coded. M108 would not be valid.
 **16 bit number.

OpenNet Controller Addressing

The default data types are shown in **bold**.

Data Types

Device Type	Reference	Data Type
I/O	I, Q, IF IW, QW	Boolean Word , Short
Internal Relays	M MW	Boolean Word , Short
Shift Registers	R RW	Boolean Word , Short
Link Registers	Lxxxx Lxxxx.yy	Word , Short Boolean

Timers/Counters	T, C TW, TP, CW, CP HW, HP	Boolean Word , Short DWord , Long
Data Registers	DW	Word , Short, DWord, Long, Float

Address Specifications

The following memory map is open from 0 to 9999 for all memory types to support newer devices. Consult the manufacturer's documentation for device specific address ranges.

Address	Reference	Range	Access
Input Bits/Words	I<xxxx>, IW<xxxx> xxxx-Bit Number*	I0-I9997, IW0-IW9997	Read Only
Force Input Bits	IF<xxxx> xxxx-Bit Number*	IF0-IF9997	Read/Write
Output Bits/Words	Q<xxxx>, QW<xxxx> xxxx-Bit Number*	Q0-Q9997, QW0-QW9997	Read/Write
Internal Relay Bits/Words	M<xxxx>, MW<xxxx> xxxx-Bit Number*	M0-M9997, MW0-MW9997	Read/Write
Shift Register Bits/Words	R<xxxx>, RW<xxxx> xxxx-Bit Number	R0-R9999, RW0-RW9999	Read/Write
Link Register	L<xxxx> xxxx-Bit Number*	L0-L9997	Read/Write
Link Register Bit Access	L<xxxx>.<yy> <xxxx>-register number* <yy>-bit number	<xxxx>: 100-127, 200-227, 300-327, 400-427, 500-527, 600-627, 700-727, 1000-1317 <yy>: 0-15	Read/Write
Counter Bits	C<xxxx> xxxx-Bit Number	C0-C9999	Read Only
Counter Words	CW<xxxx> xxxx-Word Number**	CW0-CW9999	Read Only
Counter Presets	CP<xxxx> xxxx-Word Number**	CP0-CP9999	Read/Write
Timer Bits	T<xx> xxxx-Bit Number	T0-T9999	Read Only
Timer Words	TW<xxxx> xxxx-Word Number**	TW0-TW9999	Read Only
Timer Presets	TP<xxxx> xxxx-Word Number**	TP0-TP9999	Read/Write
High Speed Counter Accumulators	HW<xxxx> xxxx-HSC Accumulator Number***	HW0-HW9999	Read Only
High Speed Counter Presets	HP<xxxx> xxxx-HSC Preset Number***	HP0-HP9999	Read Only
Data Registers	DW<xxxx> xxxx-Word Number DS<xxxx>.<yyy> xxxx-Word Number yyy-String Length (characters)	DW0-DW9999 DS0.0 ... DS0.128 DS9999.0 ... DS9999.128	Read/Write Read/Write
Calendar/Clock	WW<x> x-Word Number	WW0-WW6	Read/Write

*Low digit octal coded.

**16 bit number.

***32 bit number.

Calendar/Clock Word Numbers

0	Year (0=2000, 1=2001, etc)
1	Month
2	Day
3	Day of week (0=Sunday, 1=Monday, etc)

4	Hour (24 hour format)
5	Minute
6	Second

Examples

M180	Internal relay bits 180.*
TP65	Preset value for timer 65.**
TW65	Accumulator value for timer 65.**
DS10.24	String data stored in DW10-DW21.
WW2	Day of the month.

*Lowest digit octal coded. M108 would not be valid.

**16 bit number.

FA2 Addressing

The default data types are shown in **bold**.

Data Types

Device Type	Reference	Data Type
I/O	I, Q, IF IB, QB	Boolean Byte, Char
Internal Relays	M MB	Boolean Byte, Char
Shift Registers	R RB	Boolean Byte, Char
Timers/Counters	T, C TW, TP, CW, CP	Boolean Word , Short
Data Registers	DW	Word , Short

Address Specifications

Address	Reference	Range	Access
Input Bits/Bytes	I<xxx>, IB<xxx> xxx-Bit Number*	I0-I317, IB0-IB310	Read Only
Force Input Bits	IF<xxx> xxx-Bit Number*	IF0-IF317	Read/Write
Output Bits/Bytes	Q<xxx>, QB<xxx> xx-Bit Number*	Q0-Q317, QB0-QB310	Read/Write (bits) Read Only (bytes)
Internal Relay Bits/Bytes	M<xxx>, MB<xxx> xxx-Bit Number*	M0-M637, MB0-MB630	Read/Write (bits) Read Only (bytes)
Shift Register Bits/Bytes	R<xxx>, RB<xxx> xxx-Bit Number	R0-R127, RB0-RB120	Read/Write (bits) Read Only (bytes)
Counter Bits	C<xx> xx-Bit Number	C0-C46	Read Only
Counter Words	CW <xx> xx-Word Number**	CW0-CW46	Read Only
Counter Presets	CP<xx> xx-Word Number**	CP0-CP46	Read/Write
Timer Bits	T<xx> xx-Bit Number	T0-T79	Read Only
Timer Words	TW <xx> xx-Word Number**	TW0-TW79	Read Only
Timer Presets	TP<xx> xx-Word Number**	TP0-TP79	Read/Write
Data Registers	DW <xxx> xxx-Word Number	DW0-DW399	Read/Write

*Low digit octal coded.
 **14 bit number.

Examples

M180	Internal relay bits 180.*
TP65	Preset value for timer 65**
TW65	Accumulator value for timer 65**

*Lowest digit octal coded. M108 would not be valid.
 **14 bit number.

FA2J Addressing

The default data types are shown in **bold**.

Data Types

Device Type	Reference	Data Type
I/O	I, Q, IF IB, QB	Boolean Byte, Char
Internal Relays	M MB	Boolean Byte, Char
Shift Registers	R RB	Boolean Byte, Char
Timers/Counters	T, C TW, TP, CW, CP	Boolean Word, Short
Data Registers	DW	Word , Short

Address Specifications

Address	Reference	Range	Access
Input Bits/Bytes	I<xxx>, IB<xxx> xxx-Bit Number*	I0-I157, IB0-IB150	Read Only
Force Input Bits	IF<xxx> xxx-Bit Number*	IF0-IF157	Read/Write
Output Bits/Bytes	Q<xxx>, QB<xxx> xx-Bit Number*	Q0-Q157, QB0-QB150	Read/Write (bits) Read Only (bytes)
Internal Relay Bits/Bytes	M<xxx>, MB<xxx> xxx-Bit Number*	M0-M637, MB0-MB630	Read/Write (bits) Read Only (bytes)
Shift Register Bits/Bytes	R<xxx>, RB<xxx> xxx-Bit Number	R0-R127, RB0-RB120	Read/Write (bits) Read Only (bytes)
Counter Bits	C<xx> xx-Bit Number	C0-C46	Read Only
Counter Words	CW<xx> xx-Word Number**	CW0-CW46	Read Only
Counter Presets	CP<xx> xx-Word Number**	CP0-CP46	Read/Write
Timer Bits	T<xx> xx-Bit Number	T0-T79	Read Only
Timer Words	TW<xx> xx-Word Number**	TW0-TW79	Read Only
Timer Presets	TP<xx> xx-Word Number**	TP0-TP79	Read/Write
Data Registers	DW<xxx> xxx-Word Number	DW0-DW399	Read/Write

*Low digit octal coded.
 **14 bit number.

Examples

M180	Internal relay bits 180.*
TP65	Preset value for timer 65.**
TW65	Accumulator value for timer 65.**

*Lowest digit octal coded. M108 would not be valid.

**14 bit number.

FA3S-CP11 Addressing

The default data types are shown in **bold**.

Data Types

Device Type	Reference	Data Type
I/O	I, Q, IF IB, QB	Boolean Byte, Char
Internal Relays	M MB	Boolean Byte, Char
Shift Registers	R RB	Boolean Byte, Char
Timers/Counters	T, C TW, TP, CW, CP	Boolean Word, Short
Data Registers	DW	Word, Short

Address Specifications

Address	Reference	Range	Access
Input Bits/Bytes	I<xxx>, IB<xxx> xxx-Bit Number*	I0-I157, IB0-IB150	Read Only
Force Input Bits	IF<xxx> xxx-Bit Number*	IF0-IF157	Read/Write
Output Bits/Bytes	Q<xxx>, QB<xxx> xx-Bit Number*	Q0-Q157, QB0-QB150	Read/Write (bits) Read Only (bytes)
Internal Relay Bits/Bytes	M<xxx>, MB<xxx> xxx-Bit Number*	M0-M637, MB0-MB630	Read/Write (bits) Read Only (bytes)
Shift Register Bits/Bytes	R<xxx>, RB<xxx> xxx-Bit Number	R0-R127, RB0-RB120	Read/Write (bits) Read Only (bytes)
Counter Bits	C<xx> xx-Bit Number	C0-C46	Read Only
Counter Words	CW<xx> xx-Word Number**	CW0-CW46	Read Only
Counter Presets	CP<xx> xx-Word Number**	CP0-CP46	Read/Write
Timer Bits	T<xx> xx-Bit Number	T0-T79	Read Only
Timer Words	TW<xx> xx-Word Number**	TW0-TW79	Read Only
Timer Presets	TP<xx> xx-Word Number**	TP0-TP79	Read/Write
Data Registers	DW<xxx> xxx-Word Number	DW0-DW399	Read/Write

*Low digit octal coded.

**14 bit number.

Examples

M180	Internal relay bits 180.*
TP65	Preset value for timer 65.**
TW65	Accumulator value for timer 65.**

*Lowest digit octal coded. M108 would not be valid.

**14 bit number.

FA3S-CP12 Addressing

The default data types are shown in **bold**.

Data Types

Device Type	Reference	Data Type
I/O	I, Q, IF IB, QB	Boolean Byte, Char
Internal Relays	M MB	Boolean Byte, Char
Shift Registers	R RB	Boolean Byte, Char
Timers/Counters	T, C TW, TP, CW, CP	Boolean Word, Short
Data Registers	DW	Word , Short

Address Specifications

Address	Reference	Range	Access
Input Bits/Bytes	I<xxx>, IB<xxx> xxx-Bit Number*	I0-I317, IB0-IB310	Read Only
Force Input Bits	IF<xxx> xxx-Bit Number*	IF0-IF317	Read/Write
Output Bits/Bytes	Q<xxx>, QB<xxx> xx-Bit Number*	Q0-Q317, QB0-QB310	Read/Write (bits) Read Only (bytes)
Internal Relay Bits/Bytes	M<xxx>, MB<xxx> xxx-Bit Number*	M0-M1317, MB0-MB1310	Read/Write (bits) Read Only (bytes)
Shift Register Bits/Bytes	R<xxx>, RB<xxx> xxx-Bit Number	R0-R223, RB0-RB216	Read/Write (bits) Read Only (bytes)
Counter Bits	C<xx> xx-Bit Number	C0-C46 C48-C102	Read Only
Counter Words	CW<xx> xx-Word Number**	CW0-CW46 CW48-CW102	Read Only
Counter Presets	CP<xx> xx-Word Number**	CP0-CP46 CP48-CP102	Read/Write
Timer Bits	T<xx> xx-Bit Number	T0-T255	Read Only
Timer Words	TW<xx> xx-Word Number**	TW0-TW255	Read Only
Timer Presets	TP<xx> xx-Word Number**	TP0-TP255	Read/Write
Data Registers	DW<xxx> xxx-Word Number	DW0-DW999 DW3000-DW3071	Read/Write

*Low digit octal coded.

**14 bit number.

Examples

M180	Internal relay bits 180.*
TP65	Preset value for timer 65.**
TW65	Accumulator value for timer 65.**

*Lowest digit octal coded. M108 would not be valid.

**14 bit number.

Automatic Tag Database Generation

The Idec Serial Driver utilizes the OPC server's Automatic Tag Database Generation feature, which automatically creates tags that correspond to data points used by the device's ladder program. A tag information file is required to generate tags, and is created with the Idec WindLDR programming application (version 4.14 or higher).


The automatic tag database generation feature is customizable. The tag generation settings can be accessed by clicking **Device Properties | Database Creation**. For more information, refer to the OPC server's help documentation.

Creating the Tag Information File

A tag information file must be prepared for the target device before tags can be automatically generated. For more information, refer to the instructions below.


1. Start the WndLDR device programming application. Then, load the ladder project that will be run by the target device.
2. In the main menu, click **Edit | Tag Name Editor** to view the current list of tags.

Note: This list is automatically updated as the ladder program is created. Tags not used by the current ladder may be added or removed, and existing tags may be edited. The driver will create tags with names as they appear in the editor. Allocation numbers will be converted to the appropriate address strings. Tag name comments will appear as tag descriptions in the server. Users should review all operands because they will be used by the automatic tag generator.



3. When satisfied with the tag name list, click **Close**.

- To save the tag name data to a tag information file, select **File | Export Tag Information**.



Configuring the Driver

Once the tag information file has been created for a particular device, the driver must be configured to use it. For more information, refer to the instructions below.

- To start, open the **Device Properties** for the device of interest.
- Next, select the **Tag Import Settings** tab. For more information, refer to [Tag Import Settings](#).
- Manually enter the location of the device's tag information file. Alternatively, click the **Browse** button and then locate the tag information file.
- Select the **Database Creation** tab and configure as desired.

The OPC server's Event Log will show when the automatic tag generation feature is enabled, any errors that occurred during processing, and when the generation process completed. For more information, refer to the OPC server's help documentation.

Note 1: At this time, WndLDR does not explicitly export data type information. As such, the driver must assign its default data type to all generated tags. Address mnemonics and data types of generated tags may need to be adjusted to match the ladder program.

Note 2: Records for numerical timer and counter presets will be ignored.

Note 3: Three tags will be created for each reference to a timer and counter: current value, output bit, and preset.

Error Descriptions

The following error/warning messages may be generated. Click on the link for a description of the message.

Address Validation

[Missing address](#)

[Device address '<address>' contains a syntax error](#)

[Address '<address>' is out of range for the specified device or register](#)

[Device address '<address>' is not supported by model '<model name>'](#)

[Data Type '<type>' is not valid for device address '<address>'](#)

[Device address '<address>' is Read Only](#)

Serial Communications

[COMn does not exist](#)

[Error opening COMn](#)

[COMn is in use by another application](#)

[Unable to set comm parameters on COMn](#)

[Communications error on '<channel name>' \[<error mask>\]](#)

Device Status Messages

[Device '<device name>' is not responding](#)

[Unable to write to '<address>' on device '<device name>'](#)

Device Specific Messages

[Bad address in block \[<start address> to <end address>\] on device '<device name>'](#)

Automatic Tag Database Generation Messages

[Tag '<tag name>' not imported because model does not support type](#)

[Error parsing import file record number <record number>](#)

[Import file record <record number> could not be processed due to buffer overflow](#)

[Exception encountered during tag import. Bad tag information file](#)

[Tag import failed due to low memory resources](#)

[Description truncated for import file record number <record number>](#)

[Imported tag name '<old name>' is invalid. Name changed to '<new name>'](#)

Address Validation

The following error/warning messages may be generated. Click on the link for a description of the message.

Address Validation

[Missing address](#)

[Device address '<address>' contains a syntax error](#)

[Address '<address>' is out of range for the specified device or register](#)

[Device address '<address>' is not supported by model '<model name>'](#)

[Data Type '<type>' is not valid for device address '<address>'](#)

[Device address '<address>' is Read Only](#)

Missing address

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically has no length.

Solution:

Re-enter the address in the client application.

Device address '<address>' contains a syntax error

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically contains one or more invalid characters.

Solution:

Re-enter the address in the client application.

Address '<address>' is out of range for the specified device or register

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically references a location that is beyond the range of supported locations for the device.

Solution:

Verify that the address is correct; if it is not, re-enter it in the client application.

Device address '<address>' is not supported by model '<model name>'

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically references a location that is valid for the communications protocol but not supported by the target device.

Solution:

Verify that the address is correct; if it is not, re-enter it in the client application. Also verify that the selected model name for the device is correct.

Data Type '<type>' is not valid for device address '<address>'

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically has been assigned an invalid data type.

Solution:

Modify the requested data type in the client application.

Device address '<address>' is Read Only

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically has a requested access mode that is not compatible with what the device supports for that address.

Solution:

Change the access mode in the client application.

Serial Communications

The following error/warning messages may be generated. Click on the link for a description of the message.

Serial Communications

[COMn does not exist](#)

[Error opening COMn](#)

[COMn is in use by another application](#)

[Unable to set comm parameters on COMn](#)

[Communications error on '<channel name>' \[<error mask>\]](#)

COMn does not exist

Error Type:

Fatal

Possible Cause:

The specified COM port is not present on the target computer.

Solution:

Verify that the proper COM port has been selected in the Channel Properties.

Error opening COMn

Error Type:

Fatal

Possible Cause:

The specified COM port could not be opened due to an internal hardware or software problem on the target computer.

Solution:

Verify that the COM port is functional and may be accessed by other Windows applications.

COMn is in use by another application

Error Type:

Fatal

Possible Cause:

The serial port assigned to a device is being used by another application.

Solution:

Verify that the correct port has been assigned to the channel.

Unable to set comm parameters on COMn

Error Type:

Fatal

Possible Cause:

The serial parameters for the specified COM port are not valid.

Solution:

Verify the serial parameters and make any necessary changes.

Communications error on '<channel name>' [<error mask>]

Error Type:

Serious

Error Mask Definitions:

B = Hardware break detected.

F = Framing error.

E = I/O error.

O = Character buffer overrun.

R = RX buffer overrun.

P = Received byte parity error.

T = TX buffer full.

Possible Cause:

1. The serial connection between the device and the Host PC is bad.
2. The communication parameters for the serial connection are incorrect.

Solution:

1. Verify the cabling between the PC and the PLC device.
2. Verify that the specified communication parameters match those of the device.

Device Status Messages

The following error/warning messages may be generated. Click on the link for a description of the message.

Device Status Messages

[Device '<device name>' is not responding](#)
[Unable to write to '<address>' on device '<device name>'](#)

Device '<device name>' not responding

Error Type:

Serious

Possible Cause:

1. The serial connection between the device and the Host PC is broken.
2. The communication parameters for the serial connection are incorrect.
3. The named device may have been assigned an incorrect Network ID.

Solution:

1. Verify the cabling between the PC and the PLC device.
2. Verify that the specified communication parameters match those of the device.
3. Verify that the Network ID given to the named device matches that of the actual device.

Unable to write to '<address>' on device '<device name>'

Error Type:

Serious

Possible Cause:

1. The serial connection between the device and the Host PC is broken.
2. The communication parameters for the serial connection are incorrect.
3. The named device may have been assigned an incorrect Network ID.

Solution:

1. Verify the cabling between the PC and the PLC device.
2. Verify that the specified communication parameters match those of the device.
3. Verify that the Network ID given to the named device matches that of the actual device.

Device Specific Messages

The following error/warning messages may be generated. Click on the link for a description of the message.

Device Specific Messages

[Bad address in block \[<start address> to <end address>\] on device '<device name>'](#)

Bad address in block [<start address> to <end address>] on device '<device name>'

Error Type:

Serious

Possible Cause:

An attempt has been made to reference a nonexistent location in the specified device.

Solution:

Verify the tags assigned to addresses in the specified range on the device and eliminate ones that reference invalid locations.

Automatic Tag Generation Messages

The following error/warning messages may be generated. Click on the link for a description of the message.

Automatic Tag Generation Messages

[Tag '<tag name>' not imported because model does not support type](#)
[Error parsing import file record number <record number>](#)

[Import file record <record number> could not be processed due to buffer overflow](#)
[Exception encountered during tag import. Bad tag information file](#)
[Tag import failed due to low memory resources](#)
[Description truncated for import file record number <record number>](#)
[Imported tag name '<old name>' is invalid. Name changed to '<new name>'](#)

Tag '<tag name>' not imported because model does not support type

Error Type:

Warning

Possible Cause:

The tag information file contains references to operand/memory types not supported by the currently selected model.

Solution:

Verify that the model selected for the device in the driver and the WindLDR project from which the tag information file was created agree. Make appropriate model changes.

See Also:

[Address Descriptions](#)

Error parsing import file record number <record number>

Error Type:

Warning

Possible Cause:

A record in the tag information file has an incorrect format or a field was longer than expected.

Solution:

Verify the format of the tag information file using a text editor. Fields should be delineated by tabs and end with a new line character. Tag name and allocation numbers are assumed to be 31 characters or less and tag descriptions are assumed to be 64 characters or less. Make necessary changes to file.

Import file record <record number> could not be processed due to buffer overflow

Error Type:

Warning

Possible Cause:

A tag information file record is too long to fit into the memory buffer used for record processing.

Solution:

Records are assumed to be 128 characters long or less. Make necessary changes to the file.

Exception encountered during tag import. Bad tag information file

Error Type:

Warning

Possible Cause:

The tag information file is unreadable.

Solution:

Recreate the tag information file.

Tag import failed due to low memory resources

Error Type:

Warning

Possible Cause:

Memory needed to process the tag information file could not be allocated.

Solution:

Free up system resources and try again.

Description truncated for import file record number <record number>

Error Type:

Warning

Possible Cause:

The specified tag description is longer than the 64 character limit imposed by the OPC server.

Solution:

The driver will automatically truncate the description. Shortening tag descriptions by using WindLDR's tag name editor will ensure that all important information is maintained.

Imported tag name '<old name>' is invalid. Name changed to '<new name>'

Error Type:

Warning

Possible Cause:

The tag name given in the tag information file is not a valid OPC server name. Valid names must be composed entirely of letters, number, and underscores, and not start with an underscore.

Solution:

The driver will automatically rename the tag by replacing invalid characters. If the first character is invalid, it will be substituted with a zero. All other invalid characters will be substituted with underscores. If desired, change the tag names in the ladder project using WindLDR's tag name editor for consistency.

Index

A

Address '<address>' is out of range for the specified device or register.....	20
Address Descriptions.....	8
Address Validation.....	19
Automatic Tag Database Generation.....	17
Automatic Tag Generation Messages.....	22

B

Bad address in block [<start address> to <end address>] on device '<device name>'.....	22
Boolean.....	7
Byte.....	7

C

Char.....	7
Communications error on '<channel name>' [<error mask>].....	21
COMn does not exist.....	21
COMn is in use by another application.....	21

D

Data Type '<type>' is not valid for device address '<address>'.....	20
Data Types Description.....	7
Description truncated for import file record number <record number>.....	24
Device '<device name>' not responding.....	22
Device address '<address>' contains a syntax error.....	19
Device address '<address>' is not supported by model '<model name>'.....	20
Device address '<address>' is Read Only.....	20
Device ID.....	5
Device Setup.....	5
Device Specific Messages.....	22
Device Status Messages.....	22

E

Error Descriptions.....	19
Error opening COMn.....	21
Error parsing import file record number <record number>.....	23
Exception encountered during tag import. Bad tag information file.....	23

F

FA2 Addressing.....	13
---------------------	----

FA2(J) - CP11/12 - Cable Link Setup.....	6
FA2J Addressing.....	14
FA3S-CP11 Addressing.....	15
FA3S-CP12 Addressing.....	16
Framing.....	21
I	
Import file record <record number> could not be processed due to buffer overflow.....	23
Imported tag name <old name> is invalid. Name changed to <new name>.....	24
M	
Mask.....	21
Micro1 Addressing.....	8
Micro3 Addressing.....	9
Micro3 Contollers - RS232/RS485 Data Terminal Connection.....	6
MicroSmart Addressing.....	10
Missing address.....	19
Modem Setup.....	5
N	
Network.....	5
O	
OpenNet Controller Addressing.....	11
Overrun.....	21
Overview.....	4
P	
Parity.....	21
S	
Serial Communications.....	20
Short.....	7
T	
Tag <tag name> not imported because model does not support type.....	23
Tag import failed due to low memory resources.....	23
Tag Import Settings.....	5
U	
Unable to set comm parameters on COMn.....	21
Unable to write tag '<address>' on device '<device name>'.....	22

W

Word..... 7